



RK Occupational & Environmental Analysis Inc.

401 St. James Ave. Phillipsburg, N.J. 08865
Telephone: 908-454-6316 Fax: 908-454-4818
rkenvironmental@entermail.net

Mold Assessment
and Remediation

April 7, 2022

Health/Safety and
Environmental
Regulatory
Compliance

Mr. Charles Smith
Supervisor of Building & Grounds
Little Falls Board of Education
36 Stevens Avenue
Little Falls, NJ 07424

Right-To-Know

re: **Water Sampling for Compliance with N.J.A.C. 6A:26-12.4
Lead in Drinking Water**

OSHA/EPA/DOT
Training Programs

Dear Mr. Smith,

Asbestos and Lead
Management

We enclose the following documents and related information for compliance with the NJ Department of Education Regulation related to Lead in Drinking Water in school buildings:

Industrial Hygiene/
OSHA Compliance

Sampling Report Narrative	4 pages
Water Sampling Log and Results	3 pages
Laboratory Analytical Report	25 pages

Indoor Air Quality

All sample results for Lead were below the NJ Standard of 0.015 mg/L. In fact, 16 of the 18 water samples had no detectible Lead present in the samples. The other 2 sample results were barely above the laboratory detection limit of 0.001 mg/L

Underground/
Aboveground
Storage Tanks

If you have any questions, please don't hesitate to call us.

Environmental
Site Assessment

Sincerely,

Patrick D. McGuinness, MS, P.E.
Vice President

Hazardous/
Medical Waste
Management

PDM/

(file \Reports\Watertest\Little Falls-221)

Environmental
Audits

Expert Witness/
Litigation Support

Customized
Software

Sampling Report - Lead in Drinking Water
Little Falls School District

1. Sampling Results Summary and Statistics

Sample Collection Date	March 09, 2022
Number of Buildings Sampled	3
Total Number of Samples Collected	18
Number of Samples with No Detectible Lead	16
Number of Samples Exceeding 15 PPB (0.015 mg/L Standard)	0
Number of Samples Exceeding 5 PPB (0.005 mg/L EPA threshold)	0
Highest Measured Lead Content (mg/L)	0.0013

2. Water Sampling Procedures

Sampling protocols and procedures follow the EPA “3-T’s Program” that was developed for schools and Child Care centers. They recognize that the typical school building is actually a conglomeration of an original building with one or more additions, each of which typically having different plumbing system materials.

In addition, building sections constructed before 1986 likely have plumbing systems that used leaded solders on Copper water lines. Very old buildings and public water supply systems may also still have lead piping. Other potential sources of Lead in drinking water systems include brass faucets, fittings, along with valve seats and stems that are used in the municipal and building piping distribution systems. It is important to note that “Lead-Free” plumbing components used since 1986 may actually contain up to 8% Lead by weight. In January 2014, this limit was lowered from 8% to 0.2% Lead.

The sampling protocol requires that water be collected as a “First-Draw” to ensure that the water sample has been standing for at least 8 hours. This is intended to replicate a “worst-case” situation since both the Lead levels are usually lowered significantly after running the water even for a few moments.

Drinking water samples were collected early on a weekday (not Monday) or Saturday morning before staff and students arrived for classes to represent water that has sat idle in the building piping system overnight.

All samples were collected in 250 ml contaminant-free containers. Laboratory analysis of the water samples was performed by Pace Analytical Services, LLC of Melville, NY (NJ DEP Certification Nos. NY158). The analytical method is per EPA Method 200.8 via atomic absorption, induction coupled plasma technique.

3. Sample Results and Discussion

Sampling results are discussed below and the sampling log is appended to this report. It is important to note that the laboratory results are reported in terms of micrograms per liter ($\mu\text{g/L}$). This is essentially equivalent to parts of Lead per billion (ppb) parts of water. The Action level also translates to 15 ppb.

A total of 18 water samples were collected on March 09, 2022. None of the samples exceeded the 0.015 mg/L Action Level. In fact, 16 of the 18 water samples had no detectible levels of lead present.

4. Recommendations and Future Work

All water sample results showed acceptable results for Lead content. The following responses include those required by N.J.A.C. 6A:26-12.4 and our recommendations to maintain the drinking water quality as it relates to Lead contamination.

The NJDOE regulations requires that:

- These sampling results be made publically available at the school building and on the School District's website.
- The School District shall collect drinking water samples and analyze for Lead at any drinking water outlet that has been replaced or after any alterations to the plumbing or service lines to the outlet. Do not consume or cook with water from the affected outlet until acceptable Lead results are obtained.
- Repeat water sampling within 3 years of the date of this sampling or before March 2025.

In addition, we suggest that the following responses to minimize the potential for Lead contamination of drinking water:

Administrative Responses:

- There are several factors that influence the potential for Lead corrosion in drinking water piping systems. These include the chemistry of the water supplied being supplied to the building, water temperature and velocity through the piping, the age and condition of the plumbing, and the amount of time the water sits "stagnant" in contact with piping and drinking water fixtures. This last factor is the only one that a building owner has any control of.
- School building codes require a minimum of one (1) drinking water tap for every 100 students of building capacity. Wherever a larger number of water taps exists, the usage factor for each tap decreases. This, in turn, increases the "stagnation time" along with the increased potential for Lead corrosion. It is recommended that the need for all current water taps be investigated and reduced where appropriate while maintaining the minimum of 1 tap per 100 students.

- Consider implementing a program to shut-off and replace (if needed) any drinking water fixture of appliance that is more than 35 years old (was installed before the 1986 Lead Ban took effect).

Operational and Maintenance Responses:

- EPA recommends that any water tap where the measured Lead content exceeds 5 parts per billion (PPB) or 5 $\mu\text{g/L}$ be inspected and cleaned of line sediment to eliminate potential sources of Lead contamination. There were 2 water samples above this level.
- Use cold water only for drinking or cooking. Higher water temperatures will increase the water's corrosion potential.
- The accumulation of line sediment on aerators and screens at the water taps is frequently the source of high levels of Lead. It is recommended that a program be established to regularly inspect for the presence of line sediment at all drinking water taps. Initially, an annual inspection is suggested. The inspection frequency should then be adjusted depending upon the amounts of sediment that is found and where it is found. Higher usage taps may accumulate sediment more quickly and need to be cleaned more often.
- It is known that flushing water through drinking water taps will reduce the levels of both Lead and Copper present in the drinking water. It is also recommended that a program be established to run water at all drinking or cooking taps for at least one minute before students and staff return to school after long breaks, especially after the Summer recess.

Report prepared by:



Patrick D. McGuinness, MS, P.E.

Vice President

Water Sampling Log

Name of Building: Little Falls School No. 1
 Building Owner: Little Falls BOE

Date Collected: 09-Mar-22
 Sample Collected by: Alex Lahey

Sample No.	Sample Type	Type of Outlet	Mfg/Model Serial No.	Date Installed	Location	Time	Results (µg/L)	
							Cu	Pb
RK-030922-01	1st	Faucet		-	Kitchen	7:21	X	ND
RK-030922-02	1st	Bottle Filler	Elkay	-	Hallway - Opposite of All Purpose Room	7:23	X	ND
RK-030922-03	1st	Bottle Filler	Elkay	-	Hallway - Next to Rm 113	7:25	X	ND
RK-030922-04	1st	Water Cooler	Avalon	-	Board Office	7:28	X	ND
RK-030922-05	1st	Faucet		-	Nurse's Office - Sink Next to Restroom	7:29	X	ND
RK-030922-06	1st	Bottle Filler	Elkay	-	2nd Floor - Next to Girls Bathroom	7:33	X	ND
RK-030922-07	1st	Faucet		-	Faculty Lounge	7:34	X	ND
RK-030922-08	1st	Bottle Filler	Elkay	-	2nd Floor - Next to Boys Bathroom	7:36	X	ND

Sample Type: **1st**: First Draw sample collected after water sat in pipe between 8 and 18 hours
Flushed: Water flushed through tap for at least 2 minutes
ND: Not Detected at or above the method Reporting Level (RL) of 1.0 µg/L

Water Sampling Log

Name of Building: Little Falls School No. 2

Date Collected: 09-Mar-22

Building Owner: Little Falls BOE

Sample Collected by: Alex Lahey

Sample No.	Sample Type	Type of Outlet	Mfg/Model Serial No.	Date Installed	Location	Time	Results (µg/L)	
							Cu	Pb
RK-030922-11	1st	Bottle Filler	Elkay	-	1st Floor - Across from Storage	7:46	X	ND
RK-030922-12	1st	Faucet		-	Nurse's Office - Sink	7:49	X	ND
RK-030922-13	1st	Faucet		-	Kitchen	7:51	X	1.3
RK-030922-14	1st	Bottle Filler	Elkay	-	2nd Floor Bottle Filler	7:54	X	ND
RK-030922-15	1st	Bottle Filler	Elkay	-	3rd Floor Bottle Filler	7:55	X	ND

Sample Type: **1st**: First Draw sample collected after water sat in pipe between 8 and 18 hours
Flushed: Water flushed through tap for at least 2 minutes
ND: Not Detected at or above the method Reporting Level (RL) of 1.0 µg/L

Water Sampling Log

Name of Building: Little Falls School No. 3
 Building Owner: Little Falls BOE

Date Collected: 09-Mar-22
 Sample Collected by: Alex Lahey

Sample No.	Sample Type	Type of Outlet	Mfg/Model Serial No.	Date Installed	Location	Time	Results (µg/L)	
							Cu	Pb
RK-030922-21	1st	Bottle Filler	Elkay	-	Outside of Main Office	8:09	X	ND
RK-030922-22	1st	Bottle Filler	Elkay	-	Across Gifted and Talented Room	8:11	X	ND
RK-030922-23	1st	Faucet		-	Nurse's Office - Sink	8:12	X	ND
RK-030922-24	1st	Bottle Filler	Elkay	-	3rd Floor - Across from 301	8:15	X	ND
RK-030922-25	1st	Faucet		-	Faculty Lounge - Sink	8:16	X	1.1

Sample Type: **1st**: First Draw sample collected after water sat in pipe between 8 and 18 hours
Flushed: Water flushed through tap for at least 2 minutes
ND: Not Detected at or above the method Reporting Level (RL) of 1.0 µg/L